FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

NCS. Net Concentrator System.

 $NI/I/2/ABCD/T3C Ta = 85^{\circ}C$; T4 Ta = 60°C; T4A Ta = 40°C

EIM. Ethernet Interface Module.

MIM. MODBUS Interface Module.

AIM. Analog Input Module.

AOM. Analog Output Module.

TIM. Temperature Input Module.

DIM. Discrete Input Module.

ROM. Relay Output Module.

CPM. Concentrator Power Module.

EMM. Ethernet MODBUS Module.

Special Conditions of Use:

- 1. The Model NCS NET Concentrator System shall be installed in a final enclosure meeting the requirements of ANSI/ISA 61010-1 and the National Electrical code®.
- 2. The Model NCS NET Concentrator System shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 3. No connections shall be made to the communications "COM" port, "Ethernet", and or "USB" port in Hazardous (Classified) Locations.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; Temperature Class T3C Ta = 85° C; Temperature Class T4 Ta = 60° C; Temperature Class T4A Ta = 40° C; indoor Hazardous (Classified) Locations.

FM Approved for:

Moore Industries-International Inc. North Hills, CA 91343

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600 1998 Class 3611 2004 Original Project ID: 3029695 Approval Granted: February 6, 2008

Subsequent Revision Reports / Date Approval Amended

Report Number Date Report Number Date

3042404 July 21, 2011

FM Approvals LLC

J. E. Marquedant

Group Manager, Electrical

9.8. Manqueralint

21 July 2011

Date

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

NCS. Net Concentrator System.

IPA/2/ABCD/ T3C Ta = 85°C; T4 Ta = 60°C; T4A Ta = 40°C

EIM. Ethernet Interface Module.

MIM. MODBUS Interface Module.

AIM. Analog Input Module.

AOM. Analog Output Module.

TIM. Temperature Input Module.

DIM. Discrete Input Module.

ROM. Relay Output Module.

CPM. Concentrator Power Module.

EMM. Ethernet MODBUS Module.

Special Conditions of Use:

- 1. The Model NCS NET Concentrator System shall be installed in a final enclosure meeting the requirements of C22.2 No. 1010.1 and the Canadian Electrical code.
- 2. The Model NCS NET Concentrator System shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 3. No connections shall be made to the communications "COM" port, "Ethernet", and or "USB" port in Hazardous Locations.

Equipment Ratings:

Class I, Division 2, Groups A, B, C, and D; Temperature Class T3C Ta = 85° C; Temperature Class T4 Ta = 60° C; Temperature Class T4A Ta = 40° C; indoor Hazardous Locations.

FM Approved for:

Moore Industries-International Inc. North Hills, CA 91343

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 213 1987 CSA C22.2 No. 1010-1 2005

Approval Granted: February 6, 2008

Group Manager, Electrical

Original Project ID: 3029695C

Subsequent Revision Reports / Date Approval Amended