

CERTIFICATE OF COMPLIANCE

Certificate Number 20190808-E365227
Report Reference E365227-20190731
Issue Date 2019-AUGUST-08

Issued to: MOORE INDUSTRIES - INTERNATIONAL INC
16650 SCHOENBORN ST
NORTH HILLS CA 91343

**This certificate confirms that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS LOCATIONS

See addendum page.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 121201, NONINCENDIVE ELECTRICAL EQUIPMENT
FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III,
DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED)
LOCATIONS, and CSA C22.2 NO. 213, NONINCENDIVE
ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II,
DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2
HAZARDOUS (CLASSIFIED) LOCATIONS


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE


Certificate Number 20190808-E365227
Report Reference E365227-20190731
Issue Date 2019-AUGUST-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power Circuit and Motor-mounted Apparatus for use in Class I, Division 2, Groups A, B, C, and D Hazardous Locations.

Series ECT, followed by 4-20mA or 0-150Vdc, followed by 4-20mA, followed by 12-42Vdc.

SIX, followed by 4-20mA, 10mA-50mA, or 0-150Vdc, followed by 4-20mA or 10mA-50mA, followed by 12-42Vdc



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

