



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1097242 (LR 28549)

Master Contract: 152564

Project: 1097242 (Edition 1)

Date Issued: September 15, 2000

Issued to: **Moore Industries - International Inc.**
16650 Schoenborn St.
Sepulveda, CA 91343-6196

The products listed below are eligible to bear the CSA Mark shown



Issued by: Andrew Redeker, C.E.T.

Signature: P Andrew Redeker

CLASS

2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

PRODUCTS

Class I, Division 1, Groups A,B,C and D; Class II, Division 1, Groups E, F and G; Class III

Model IPH Current to Pressure Transmitter; Intrinsically Safe when installed as per Drawing Number 100-100-53; Entity Parameters $V_{max} = 30V_{dc}$, $I_{max} = 85mA$, $P_{max} = 0.6375W$, $C_i = 0\mu F$, $L_i = 5mH$; Temperature Code T6; Ambient Temperature $-40^{\circ}C$ to $+60^{\circ}C$; Enclosure Type 4X.

CLASS

2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non-Incendive Systems - For Hazardous Locations

PRODUCTS

Class I, Division 1, Groups A,B,C and D; Class II, Division 1, Groups E, F and G; Class III

Model IPH Current to Pressure Transmitter; Input rated 30Vdc max, 20mA; Intrinsically Safe when installed as per Drawing Number 100-100-53; Temperature Code T6; Ambient Temperature $-40^{\circ}C$ to $+60^{\circ}C$; Enclosure Type 4X



CSA INTERNATIONAL

Certificate: 1097242

Master Contract: 152564

Project: 1097242

Date Issued: September 15, 2000

CLASS

2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

PRODUCTS

Class I, Division 2, Groups A,B,C and D; Class II, Division 2, Groups F and G; Class III

Model IPH Current to Pressure Transmitter; Input rated 30Vdc max, 20mA; Temperature Code T6; Ambient Temperature -40°C to +60°C; Enclosure Type 4X

CLASS

2252 01 - PROCESS CONTROL EQUIPMENT

PRODUCTS

Model IPH Current to Pressure Transmitter; Input rated 30Vdc max, 20mA; Enclosure Type 4X

APPLICABLE REQUIREMENTS

- CSA Standard C22.2 No 0-M1991 - General Requirements - Canadian Electrical Code Part II.
- 0.4-M1982 - Bonding and Grounding of Electrical Equipment (Protective Grounding).
- 25-M1966 - Enclosures for Use in Class II Groups E, F and G Hazardous Locations.
- 94-M1991 - Special Purpose Enclosures.
- 142-M1987 - Process Control Equipment.
- 157-M1992 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations.
- 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.