

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

## CERTIFICATE OF COMPLIANCE

### HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

### IPT2/a/b/c/-d [DIN]. Current-to-Pressure Transmitter.

 $NI/I/2/ABCD/T5 Ta = -40^{\circ}C to +80^{\circ}C$ 

a= Input: 4-20mA, 4-12mA, 12-20mA

b= Output: 3-15PSIG, 15-3PSIG, 1-17PSIG, 17-1PSIG, 6-30PSIG 30-6PSIG, 3-27PSIG, 27-3PSIG, 0-20PSIG, 20-0PSIG, .2-1KGCM2, 1-.2KGCM2, 3-18PSIG, 18-3PSIG, .2-1BAR, 1-.2BAR, .02-.10MPA, .10-.02MPA,

20-100KPA or 100-20KPA.

c = Power (Air Supply): 20PSI, 25PSI, 35PSI, 1.4BAR, .14MPA, 140KPA or 1.4KGCM2.

d = Options: FA1, FA2, FA3, FA4, FA5, FA6, FA7, FA8, FA9, FA10, FA11, FA12, FMEDA, GA1, TROP, VTD.

### Special Conditions of Use:

- 1. The Model IPT<sup>2</sup> Current to Pressure Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 2. The Model IPT<sup>2</sup> Current to Pressure Transmitter shall be mounted in a tool secured enclosure when installed in a Class I, Division 2 location.
- 3. The test jacks (-T and +T) shall not be used when the Model IPT<sup>2</sup> Current to Pressure Transmitter is installed in a Class I, Division 2 location.

### **Equipment Ratings:**

Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; Temperature Class T5 Tamb =  $-20^{\circ}$ C to  $+80^{\circ}$ C; Hazardous (Classified) Locations.

#### FM Approved for:

Moore Industries International, Inc. North Hills, CA 91343-6196 USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM Class 3600	2011
FM Class 3611	2004
FM Class 3810	2005

Original Project ID: 3055461 Approval Granted: June 8, 2015

Subsequent Revision Reports / Date Approval Amended

Report Number Date Report Number Date

FM Approvals LLC

.£. Marquedant

Manager, Electrical Systems

8 June 2015

Date



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

### CERTIFICATE OF COMPLIANCE

# HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

### IPT2/a/b/c/-d [DIN]. Current-to-Pressure Transmitter.

 $NI/I/2/ABCD/T5 Ta = -40^{\circ}C to +80^{\circ}C$ 

a= Input: 4-20mA, 4-12mA, 12-20mA

b= Output: 3-15PSIG, 15-3PSIG, 1-17PSIG, 17-1PSIG, 6-30PSIG 30-6PSIG, 3-27PSIG, 27-3PSIG, 0-20PSIG, 20-0PSIG, .2-1KGCM2, 1-.2KGCM2, 3-18PSIG, 18-3PSIG, .2-1BAR, 1-.2BAR, .02-.10MPA, .10-.02MPA, 20-100KPA or 100-20KPA.

c = Power (Air Supply): 20PSI, 25PSI, 35PSI, 1.4BAR, .14MPA, 140KPA or 1.4KGCM2.

d = Options: FA1, FA2, FA3, FA4, FA5, FA6, FA7, FA8, FA9, FA10, FA11, FA12, FMEDA, GA1, TROP, VTD.

#### Special Conditions of Use:

- 1. The Model IPT<sup>2</sup> Current to Pressure Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 2. The Model IPT<sup>2</sup> Current to Pressure Transmitter shall be mounted in a tool secured enclosure when installed in a Class I, Division 2 location.
- 3. The test jacks (-T and +T) shall not be used when the Model IPT<sup>2</sup> Current to Pressure Transmitter is installed in a Class I, Division 2 location.

### **Equipment Ratings:**

Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; Temperature Class T5 Tamb = -20°C to +80°C; Hazardous Locations.

### FM Approved for:

Moore Industries International, Inc. North Hills, CA 91343-6196 USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 213-M1987 C22.2 No. 1010.1	1987 2004	(Reaffirmed 2013)	
Original Project ID: 3055461C		Approval Granted:	June 8, 2015
Subsequent Revision Reports / D	ate A		Dete
Report Number Date		Report Number	Date
FM Approvals LLC			
J. E. Marquedant			8 June 2015

Manager, Electrical Systems