

1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

***Series LH1abc, Instrument Enclosure***

Type 4X/IP66

a = Threaded conduit/process port C, N, or M.

b = Optional cover A, B, C, G, R, S or Y.

c = Type of mount P.

**Equipment Ratings:**

Environmentally rated NEMA Type 4X and IP66 for use in non-hazardous (classified) locations.

**Approved for:**

Moore Industries-International, Inc.  
Sepulveda, CA 91343-6196

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Approval Standards and other documents:

Class 3810	1989
NEMA-250	1991
ANSI/UL-50	1992
IEC-529	1989


Original Approval Job Identification: 1D8A0.AE      Approval Granted: September 29, 1997

Subsequent Revision Reports / Date Approval Amended

3001745

September 25, 1998

Factory Mutual Research Corporation



Paris Stavrianidis, Assistant Vice President  
Approvals Division

August 9, 2001  
Date