



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

PIT-DINabcd, PIXabcd. Pressure to Current Transmitter

NI / I / 2 / ABCD, T4 Ta = -20°C to +65°C

a = Input pressure range 3-15 PSIG, 3-27 PSIG, 6-30 PSIG, 20-100 kPa, 20-186 kPa, 0.2-1 BAR or 0.2-1 KGCM2.

b = Current output 4-20 mA or 10-50 mA.

c = Power input 12-42 V dc.

d = Access/mounting option FA1, FA2, FA3, FA4, FA7 and FA8 (for PIT-DIN only); HP, FL or D2 (for PIX only).

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C and D.

FM Approved for:

Moore Industries International Inc.
North Hills, California



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	1989


Original Project ID: 0R0H7.AX

Approval Granted: January 28, 1991

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
120925	November 30, 2012		

FM Approvals LLC



J.E. Marquedant
Group Manager, Electrical

30 November 2012
Date