



# Certificate of Compliance

**Certificate Number:** LR 28549-97

**Revision:** LR 28549-97

**Date Issued:** January 12, 1998

**Issued to:** Moore Industries - International Inc.  
16650 Schoenborn St.  
Sepulveda, CA 91343  
USA

*The products listed below are eligible to bear the CSA Mark*

*<sup>1</sup>NOTE: The "NRTL/C" indicator also appears adjacent to the CSA Mark.*

**Issued by:** John Chiang, P. Eng.  
Vancouver, BC Canada

**Signature:** \_\_\_\_\_

## **CLASS**

2252 01 - PROCESS CONTROL EQUIPMENT  
2252 81 - PROCESS CONTROL EQUIPMENT

## **PRODUCTS**

Temperature Transmitters, Models TRY [DIN], and SIY [DIN], input rated 42 Vdc max., 23.5 mA, output 4-20 mA.

**Note:** This equipment is certified only for use in other equipment where the suitability of the combination is to be determined.

## **APPLICABLE STANDARDS**

CSA Std C22.2 No. 142-M1987 - Process Control Equipment  
UL Standard 508 - Industrial Control Equipment

<sup>1</sup>The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.