



FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**SPA<sup>2</sup> abcd [DIN] Site Programmable Alarm**

NI / I / 2 / ABCD / T4 Ta = 85°C; T5 Ta = 50°C

a = HLPRG or TPRG

b = 2PRG or 4PRG

c = 24DC, 110DC, UAC or U

d = -AO, RF, -DPDT, -VTD, -EMP or Blank

*Special Condition of Use:*

*Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.*

### Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C and D indoor hazardous (classified) locations;  
Temperature Class T4 when Ta = 85°C and T5 Ta = 50°C.

**SPA<sup>2</sup> abcd [DIN] Site Programmable Alarm**

a = HLPRG or TPRG

b = 2PRG or 4PRG

c = 24DC, 110DC, UAC or U

d = -AO, RF, -DPDT, -VTD, -EMP or Blank

*Special Condition of Use:*

*Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.*

### Equipment Ratings:

Ordinary Locations: 24Vdc, or 110Vdc or 90Vac-260ac

### FM Approved for:

Moore Industries International Inc  
16650 Schoenborn Street  
North Hills, CA 91343

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)  
FM Approvals HLC 5/13 3027034

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	2005

Original Project ID: 3027034

Approval Granted: September 20, 2006

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3039319	July 29, 2010		
100803	August 9, 2010		
RR204562	March 24, 2016		

FM Approvals LLC



---

James E. Marquedant  
Manager, Electrical Systems

24 March 2016

---

Date



FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

**SPA<sup>2</sup> abcd [DIN] Site Programmable Alarm**

NI / I / 2 / ABCD / T4 Ta = 85°C; T5 Ta = 50°C

a = HLPRG or TPRG

b = 2PRG or 4PRG

c = 24DC, 110DC, UAC or U

d = -AO, RF, -DPDT, -VTD, -EMP or Blank

Special Condition of Use:

Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

**Equipment Ratings:**

Suitable for use in Class I, Division 2, Groups A, B, C and D indoor hazardous locations; Temperature Class T4 when Ta = 85°C and when T5 Ta = 50°C.

**SPA<sup>2</sup> abcd [DIN] Site Programmable Alarm**

a = HLPRG or TPRG

b = 2PRG or 4PRG

c = 24DC, 110DC, UAC or U

d = -AO, RF, -DPDT, -VTD, -EMP or Blank

Special Condition of Use:

Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

**Equipment Ratings:**

Ordinary Locations: 24Vdc, or 110Vdc or 90Vac-260ac

**FM Approved for:**

Moore Industries International Inc  
16650 Schoenborn Street  
North Hills, CA 91343

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No.213-M1987	1987
C22.2 No.1010.1	2004

Original Project ID: 3027034C

Approval Granted: September 20, 2006

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3039319	July 29, 2010		
100803	August 9, 2010		
RR204562	March 24, 2016		

FM Approvals LLC



---

James E. Marquedant  
Manager, Electrical Systems

24 March 2016  
Date

---