



# Certificate of Compliance

Certificate Number: LR 28549-69

Revision: LR 28549-96

Date Issued: March 2, 1998

Issued to: **Moore Industries - International Inc.**  
**16650 Schoenborn St.**  
**Sepulveda, CA 91343**  
**USA**

*The products listed below are eligible to bear the CSA Mark*

*<sup>1</sup>NOTE: The "NRTL/C" indicator also appears adjacent to the CSA Mark.*

Issued by: John Chiang, P. Eng.  
Vancouver, BC Canada

Signature: \_\_\_\_\_

## CLASS

2252 01 - PROCESS CONTROL EQUIPMENT  
2252 81 - PROCESS CONTROL EQUIPMENT

## PRODUCTS

Programmable Isolator, Models SPT and SPA, rated 22-300 V dc and 90-260 V ac, or 117/ 230 V ac for SPA/ HART option, 60 Hz, 2 W nominal, 3.5 W max, .

Note: This equipment is certified only for use in other equipment where the suitability of the combination is to be determined.

## APPLICABLE STANDARDS

CAN/CSA-C22.2 No 142-M1987	-	Process Control Equipment
UL 1092	-	Process Control Equipment
UL 508	-	Industrial Control Equipment

<sup>1</sup>The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.