

1 EC-TYPE EXAMINATION CERTIFICATE



2 Equipment or Protective systems intended for use in Potentially
Explosive Atmospheres - Directive 94/9/EC

3 EC-Type Examination Certificate No: FM10ATEX0054X

4 Equipment or protective system: MODEL TCM TEMPERATURE CONCENTRATOR MODULE
(Type Reference and Name)

5 Name of Applicant: Moore Industries International, Inc.

6 Address of Applicant: 16650 Schoenborn Street
North Hills, CA 91343
USA

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and documents therein referred to.

8 FM Approvals Ltd, notified body number 1725 in accordance with Article 9 of Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report number:

3041010EC dated 1st December, 2010

9 Compliance with the Essential Health and Safety Requirements, with the exception of those identified in item 15 of the schedule to this certificate, has been assessed by compliance with the following documents:

EN60079-0: 2006, EN60079-11:2007, and EN60079-26:2007

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC-Type Examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include:

II 1 G Ex ia IIC T4 (-40°C ≤ Ta ≤ 85°C)

T5 (-40°C ≤ Ta ≤ 40°C)



Mick Gower
Certification Manager, FM Approvals Ltd.

Issue date: 23rd April 2015

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Ltd. 1 Windsor Dials, Windsor, Berkshire, UK. SL4 1RS
T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: atex@fmaprovals.com www.fmaprovals.com

SCHEDULE

to EC-Type Examination Certificate No. FM10ATEX0054X

13 Description of Equipment or Protective System:

The Model TCM Temperature Concentrator Module accepts any combination of up to sixteen RTD, T/C, mV and resistance/potentiometer signal inputs. It converts the sensor inputs to the HART digital communications protocol and transmits the data from the file to the control room.

The operating ambient range of the TCM is specified to be -40°C to 85°C. The Model TCM consists of eight PC Boards consisting of a power supply board, a terminal board, a CPU board, a communication port board and four input boards.

The Model TCM electronics are located inside of a metallic DIN rail style housing. This housing is required to be located in a final enclosure. The housing is approximately 4.96" x 4.88" x 3.94". The front of the housing contains plug in screw type terminals. The top face of the housing contains six connector input sense devices numbered 0-5 and the bottom face of the housing consists of ten connectors for input sense devices numbered 6-15. The bottom face of the housing also contains a 2 clamp terminal connector for power (+PS and -PS). The face of the housing also contains a communication port for programming at the factory. The communications port is not for use in the explosive atmosphere.

TCM/a/HART/15-30Vdc/b/DIN. Temperature Concentrator Module.

Energy Limitation Parameters:

Ui = 30V, Ii = 110mA, Pi = 825mW, Ci = 0, Li = 0.

Energy Limitation Parameters: Field Sensor Terminals:

Uo = 4V, Io = 254.14mA, Po = 717.38mW, Co = 396µF, Lo = 9.4µH.

a= Input: TPRG, J-, K-, E-, T-, R-, S-, N-, B-, C-, MV, R1-, R2-, R3-, R4-, R5-, R6-, R7-, R8-, R9-, R10-, R11-, R12-, R13-, R14-, R0, POT.

b= Options: -TROP or-VTD.

14 Specific Conditions of Use:

1. The Model TCM Temperature Concentrator Module shall be installed in an enclosure which maintains an ingress protection rating of IP20.
2. For Zone 0 installations, the final enclosure shall not contain more than 10% in total of aluminum, magnesium, titanium and zirconium, or 7.5% in total of magnesium, titanium and zirconium; For Zone 1 installations, the final enclosure shall not contain 7.5% in total of magnesium.
3. If the final enclosure is non-metallic, under certain extreme circumstances, the non-metallic parts incorporated in the final enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore particularly when it is used for applications that specifically require group II, zone 0 located equipment, that the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. Additionally, the equipment shall only be cleaned with a damp cloth.
4. Using the box provided on the nameplate, the User shall permanently mark the protection type chosen for the specific installation. Once the type of protection has been marked it shall not be changed.
5. The COM port shall not be used in the explosive area.

15 Essential Health and Safety Requirements:

The relevant EHSRs that have not been addressed by the standards listed in this certificate have been identified and assessed in the confidential report identified in item 8.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE

to EC-Type Examination Certificate No. FM10ATEX0054X

16 Test and Assessment Procedure and Conditions:

This EC-Type Examination Certificate is the result of testing of a sample of the product submitted, in accordance with the provisions of the relevant specific standard(s), and assessment of supporting documentation. It does not imply an assessment of the whole production.

Whilst this certificate may be used in support of a manufacturer's claim for CE Marking, FM Approvals Ltd accepts no responsibility for the compliance of the equipment against all applicable Directives in all applications.

This Certificate has been issued in accordance with FM Approvals Ltd's ATEX Certification Scheme.

17 Schedule Drawings

A list of the significant parts of the technical documentation is annexed to this certificate and a copy has been kept by the Notified Body.

18 Certificate History

Details of the supplements to this certificate are described below:

Date	Description
3 rd December 2010	Original Issue.
23 rd April 2015	Supplement 1: Report Reference: – 3041010rev141212 dated 6 th April 2015. Description of the Change: Changes include reconfiguration of PCB connectors, minor component layout changes and related documentation updates.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE