



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

TDZ²/a/4-20mA/b/-c [d]. Temperature Transmitter.

IS/I/1/ABCD/T4 Ta = 85°C – 100-100-71; Entity; I/O/AEx ia IIC T4 Ta = 85°C – 100-100-71; Entity; NI/I/2/ABCD/T4 Ta = 85°C

Entity Parameters:

Vmax = 30V, Imax = 110, Pi = 825mW, Ci = 5.83nF, Li = 0mH.

Field Sensor Terminals:

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20μF, La = 25mH (Groups A, B).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 498μF, La = 100mH (Groups C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20μF, La = 200mH (Group D).

a = Input: TPRG, HLRPG, 2TPRG, C, B, E, J, K, N, R, S, T, MV, R1, R2, R3, R4, R5, R6, R7, R8, R9, R10, R11, R12, R13, R14, RO or POT.

b = Power: 12-42DC or 12-30DC. (12-42DC not for Intrinsically Safe Installations)

c = Options: TROP, HS, VTB, VTD, FMEDA.

d = Housing options: HP, BH or D.

Special Conditions of Use:

1. The Model TDZ² Temperature Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Equipment ratings:

Intrinsically Safe (Entity) for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T4 Ta = 85°C in accordance with Control Drawing No.100-100-71; Intrinsically safe (Entity) for use in Class I, Zone 0, AEx ia IIC T4 Ta = 85°C; in accordance with Control Drawing No.100-100-71; Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; Temperature Class T4 Ta = 85°C; indoor Hazardous (Classified) Locations.

THZ²/a/4-20mA/b/-c [d]. Temperature Transmitter.

IS/I/1/ABCD/ T5 Ta = 85°C; T6 Ta = 60°C – 100-100-71; Entity; I/O/AEx ia IIC T5 Ta = 85°C; T6 Ta = 60°C – 100-100-71; Entity; NI/I/2/ABCD/ T5 Ta = 85°C; T6 Ta = 60°C

Entity Parameters:

Vmax = 30V, Imax = 110 Pi = 825mW, Ci = 5.83nF, Li = 0mH.

Field Sensor Terminals:

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20μF, La = 25mH (Groups A, B, C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 498 μ F, La = 100mH (Groups C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20 μ F, La = 200mH (Group D).

a = Input: TPRG, HLRPG, 2TPRG, C, B, E, J, K, N, R, S, T, MV, R1, R2, R3, R4, R5, R6, R7, R8, R9, R10, R11, R12, R13, R14, RO or POT.

b = Power: 12-42DC or 12-30DC. (12-42DC not for Intrinsically Safe Installations)

c = Options: VTB, VTD, FMEDA.

d = Housing options: HPP, D or LH1.

Special Conditions of Use:

1. The Model THZ² Temperature Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Equipment Ratings:

Intrinsically Safe (Entity) for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T5 Ta = 85°C; T6 Ta = 60°C in accordance with Control Drawing No.100-100-71; Intrinsically safe (Entity) for use in Class I, Zone 0, AEx ia IIC T5 Ta = 85°C; T6 Ta = 60°C in accordance with Control Drawing No.100-100-71; Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; T5 Ta = 85°C; T6 Ta = 60°C; indoor Hazardous (Classified) Locations.

888/TPRG/4-20mA/a-b [c]. Temperature Transmitter.

IS/I/1/ABCD/ T5 Ta = 85°C; T6 Ta = 60°C – 100-100-77; Entity; I/O/AEx ia IIC T5 Ta = 85°C; T6 Ta = 60°C – 100-100-77; Entity; NI/I/2/ABCD/T5 Ta = 85°C; T6 Ta = 60°C

Entity Parameters:

Vmax = 30V, Imax = 110 Pi = 825mW, Ci = 5.83nF, Li = 0mH.

Field Sensor Terminals:

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20 μ F, La = 25mH (Groups A, B, C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 498 μ F, La = 100mH (Groups C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20 μ F, La = 200mH (Group D).

a = Power: 12-42DC or 12-30DC. (12-42DC not for Intrinsically Safe Installations)

b = Options: VTB or VTD.

c = Housing options: HPP, D or LH1.

Special Conditions of Use:

1. The Model 888 Temperature Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Equipment Ratings:

Intrinsically Safe (Entity) for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T5 Ta = 85°C; T6 Ta = 60°C in accordance with Control Drawing No.100-100-77; Intrinsically safe (Entity) for use in Class I, Zone 0, AEx ia IIC T5 Ta = 85°C; T6 Ta = 60°C in accordance with Control Drawing No.100-100-77; Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; T5 Ta = 85°C; T6 Ta = 60°C; indoor Hazardous (Classified) Locations.



Member of the FM Global Group

FM Approved for:

Moore Industries International, Inc.
North Hills, CA 91343-6196 USA

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2010
Class 3611	2004
Class 3810	2005
ANSI/ISA-60079-0	2009
ANSI/ISA-60079-11	2009

Original Project ID: 3024597

Approval Granted: May 23, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
02/08/10	March 5, 2010		
3039105	March 12, 2010		
3042210	November 15, 2011		

FM Approvals LLC

Timothy Adam
Technical Team Manager

15 Nov. 2011

Date



Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

TDZ²/a/4-20mA/b/-c [d]. Temperature Transmitter.

IS/II/1/ABCD/T4 Ta = 85°C – 100-100-71; Entity; NII/2/ABCD/T4 Ta = 85°C

Entity Parameters:

V_{max} = 30V, I_{max} = 110, P_i = 825mW, C_i = 5.83nF, L_i = 0mH.

Field Sensor Terminals:

V_t = 6.51V, I_t = 35.39mA, P_o = 57.6mW, C_a = 20μF, L_a = 25mH (Groups A, B).

V_t = 6.51V, I_t = 35.39mA, P_o = 57.6mW, C_a = 498μF, L_a = 100mH (Groups C, D).

V_t = 6.51V, I_t = 35.39mA, P_o = 57.6mW, C_a = 20μF, L_a = 200mH (Group D).

a = Input: TPRG, HLRPG, 2TPRG, C, B, E, J, K, N, R, S, T, MV, R1, R2, R3, R4, R5, R6, R7, R8, R9, R10, R11, R12, R13, R14, RO or POT.

b = Power: 12-42DC or 12-30DC. (12-42DC not for Intrinsically Safe Installations)

c = Options: TROP, HS, VTB, VTD, FMEDA.

d = Housing options: HP, BH or D.

Special Conditions of Use:

1. *The Model TDZ² Temperature Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.*

Equipment ratings:

Intrinsically Safe (Entity) for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T4 Ta = 85°C in accordance with Control Drawing No.100-100-71; Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; Temperature Class T4 Ta = 85°C; indoor Hazardous Locations.



Member of the FM Global Group

THZ²/a/4-20mA/b/-c [d]. Temperature Transmitter.

IS/II/1/ABCD/T5 Ta = 85°C; T6 Ta = 60°C – 100-100-71; Entity; NI/II/2/ABCD/ T6 Ta = 60°C

Entity Parameters:

Vmax = 30V, Imax = 110 Pi = 825mW, Ci = 5.83nF, Li = 0mH.

Field Sensor Terminals:

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20μF, La = 25mH (Groups A, B, C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 498μF, La = 100mH (Groups C, D).

Vt = 6.51V, It = 35.39mA, Po = 57.6mW, Ca = 20μF, La = 200mH (Group D).

a = Input: TPRG, HLRPG, 2TPRG, C, B, E, J, K, N, R, S, T, MV, R1, R2, R3, R4, R5, R6, R7, R8, R9, R10, R11, R12, R13, R14, RO or POT.

b = Power: 12-42DC or 12-30DC. (12-42DC not for Intrinsically Safe Installations)

c = Options: VTB, VTD, FMEDA.

d= Housing options: HPP, D or LH1.

Special Conditions of Use:

1. *The Model THZ² Temperature Transmitter shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.*

Equipment Ratings:

Intrinsically Safe (Entity) for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T5 Ta = 85°C; T6 Ta = 60°C in accordance with Control Drawing No.100-100-71; Nonincendive for use in Class I, Division 2, Groups A, B, C, and D; T5 Ta = 85°C; T6 Ta = 60°C; indoor Hazardous Locations.

FM Approved for:

Moore Industries-International, Inc.
North Hills, CA 91343 USA



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CAN C22.2 No.157-92	1992
(Re-affirmed 2006)	
CAN C22.2 No.213-M1987	1987
(Re-affirmed 2004)	
C22.2 No. 1010.1	2004

Original Project ID: 3024597C

Approval Granted: May 23, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
100208	March 5, 2010		

FM Approvals LLC

J. E. Marquedant
Group Manager, Electrical

5 March 2010
Date