

# Certificate of Conformity

## Ex EQUIPMENT

Certificate No.:	<b>ANZEx 09.3020X</b>	Current Issue:	1	Date of Issue:	2019-04-18
------------------	-----------------------	----------------	---	----------------	------------

**Applicant:** **Moore Industries International**  
16650 Schoenborn Street  
North Hills CA 91343  
U.S.A

**Equipment:** Fully Encapsulated PC-Programmable Temperature Transmitters (TRX: non-isolated; and TRY: isolated)

**Type of Explosion Protection:** Intrinsic Safety 'ia'

**Explosion Protection Marking:** Ex ia IIC T5 -20 °C ≤ T<sub>a</sub> ≤ +85 °C

*This certificate is granted subject to the conditions as set out in Standards Australia/Standards New Zealand Miscellaneous Publication **MP87.1***

Signed for and on behalf of issuing body



Name & Position

Ujen Singh, Quality & Certification Manager

*This certificate is not transferable and remains the property of the issuing body.*

*The status of this certificate can be confirmed through the database located at [www.anzex.com.au](http://www.anzex.com.au)*

Certificate issued by:

TestSafe Australia  
919 Londonderry Road, Londonderry NSW 2753 Australia

# Certificate of Conformity

## Ex EQUIPMENT

<b>Certificate No.:</b> ANZEx 09.3020X	<b>Current Issue:</b> 1	<b>Date of Issue:</b> 2019-04-18
--	-------------------------	----------------------------------

**Manufacturer :** **Moore Industries International**  
16650 Schoenborn Street  
North Hills CA 91343  
U.S.A.

**Additional  
Manufacturing  
Location(s):** 'None'

### STANDARDS:

*The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:*

<b>AS/NZS 60079-0:2005</b>	Electrical equipment for explosive gas atmospheres– Part 0: General requirements (Including Amendment 1)
<b>AS/NZS 60079.11:2006</b>	Explosive atmospheres– Part 11: Equipment protection by Intrinsic safety "I"
<b>AS 60529:2004</b>	Degree of protection provided by enclosure (IP code)

*This Certificate does not indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.*

### TEST & ASSESSMENT REPORTS:

*The equipment listed has successfully met the examination and test requirements as recorded in:*

Test Report Nos. & Issuing Bodies associated with all issues of the certificate:	30577, TestSafe
Quality Assessment Report No. & Issuing Body:	GB/FME/QAR18.0009/00 FM Approvals
File Reference:	2007/025237, 2018/020108

# Certificate of Conformity

## Ex EQUIPMENT

Certificate No.: **ANZEx 09.3020X**

Current Issue: 1

Date of Issue: 2019-04-18

### Schedule

#### Equipment Description:

The PC- Programmable Temperature Transmitter TRX: non-isolated model is fully encapsulated within a plastic enclosure and the electrical connections are provided with screw terminals on top of the plastic enclosure. There are two PCBs in this model.

The PC- Programmable Temperature Transmitter TRY: isolated model is fully encapsulated within a plastic enclosure and the electrical connections are provided with screw terminals on top of the plastic enclosure. There are three PCBs in this model.

Each model of apparatus provides a proportional 4-20 mA signal output derived from input signal of an RTD probe or a thermocouple or a milli-volt source of maximum 1000 mV. The PCB assembly is identified as HPP-Style (Hockey-Puck Housing) in the instruction manual. The power supply is connected to the screw terminals marked +PS and -PS. The temperature sensor is connected to the screw terminals marked 1, 2, 3 and 4 of the HPP model housing. The COM port is to be used only in the non-hazardous area and the parameters are given in the label drawing.

The enclosures of both TRX and TRY Transmitters are plastic. The drawing number 204-284-01 and 204-284-02 provide details of the top and bottom part of this enclosure.

#### Variations Permitted by this Issue:

1. Change of QAR issuer to FM Approvals GB/FME/QAR18.0009/00.
2. Marking label drawings changed to show ambient temperature range instead of the maximum ambient temperature.

#### Specific Conditions of Use:

1. When used in Zone 0, a warning on potential electrostatic charging hazard is required.
2. The following input and output parameters must be taken into account when installed:

Input parameters at + PS, -PS terminals:

#### TRY (isolated) and TRX (non-isolated)

$U_i = 30V$

$I_i = 110\text{ mA}$

$P_i = 825\text{ mW}$

# Certificate of Conformity

## Ex EQUIPMENT

Certificate No.: **ANZEx 09.3020X**

Current Issue: 1

Date of Issue: 2019-04-18

Ci = 5.2 nF

Li = 0 µH

Output parameters at terminals where temperature sensor is connected:**TRY Model, Terminals 1, 2, 3, 4.**

Uo = 6.51 V

Io = 205 mA

Po = 675 mW

Lo = 0.410 mH

Co = 5.1 µF

**TRX Model, Terminals 1, 2, 3, 4.**

Uo = 6.51 V

Io = 110 mA

Po = 532 mW

Lo = 1.4 mH

Co = 2.262 µF

**Additional Information:**

The infallible transformer T201 shall be subjected to routine tests as per clause 11.2 of AS/NZS 60079.11:2006.

*Manufacturer's Documents associated with this Issue:*

Document Number	Pages / Sheets	Document Title	Revision	Date
200-251-1712	1	Label, ANZEx TRX-ISA [HPP], Intrinsically Safe	B1	2019-05
200-251-1721	1	Label, ANZEx TRY-ISA [HPP], Intrinsically Safe	B1	2019-05

# Certificate of Conformity

## Ex EQUIPMENT

Certificate No.: **ANZEx 09.3020X**      Current Issue: 1      Date of Issue: 2019-04-18

### History of Issues and Variations

#### Issue 0 dated 2009-12-02

Manufacturer's Documents associated with Issue 0:

Document Number	Pages / Sheets	Document Title	Revision	Date
<b>PC Programmable Temperature Transmitter TRX: non-isolated</b>				
235-866-00	2	PC1 Bom Description	B	-
235-882-00	1	TRX PC2 Bom Description	D	-
506-551-02	1	TRX-HPP PC1 Primary Side Circuitry (PCB Art Work)	B	2002-09-06
506-551-02	1	TRX-HPP PC1 Secondary Side Circuitry (PCB Art Work)	B	2002-09-06
506-551-02	1	TRX-HPP PC1 Inner Layer 1 Circuitry (PCB Art Work)	B	2002-09-06
506-551-02	1	TRX-HPP PC1 Inner Layer 2 Circuitry (PCB Art Work)	B	2002-09-06
235-582-00	1	PC2, T2X [HPP] TRX- R [HPP], P2X [HPP] (PC Assembly)	D	2002-03
506-571-02	1	T2X [HPP] & TRX [HPP] – R PC2 Primary Side Circuitry (PCB art work)	D	2006-01-15
506-571-02	1	T2X [HPP] & TRX [HPP] – R PC2 Secondary Side Circuitry (PCB art work)	D	2006-01-15
235-466-00	1	TRX [HPP] – R Option (Schematic)	D	2004-08
235-566-00	1	PC1, TRX [HPP] – R Option (PC Assembly)	B	2002-09
235-568-00	3	Top Assembly, TRX [HPP] –R Option (PC Assembly)	A	2000-03
506-551-01	2	PC1, TRX [HPP] – R Option (PC Fabrication)	B	2002-09
506-571-01	2	PC2, T2X [HPP] & TRX [HPP]– R (PC Fabrication)	D	2006-01
200-251-1712	1	Label, ANZEx TRX-ISA [HPP], Intrinsically Safe	B	2009-10
<b>PC Programmable Temperature Transmitter TRY: isolated</b>				
235-876-00	2	PC1 Bom Description	C	-
235-877-00	2	PC2 Bom Description	B	-
235-878-00	2	List of materials PC3	F1	-

# Certificate of Conformity

## Ex EQUIPMENT

Certificate No.:	ANZEx 09.3020X	Current Issue:	1	Date of Issue:	2019-04-18
506-556-02	1	TRY [HPP] – R PC1 Primary Side	D	2002-11-22	
506-556-02	1	TRY [HPP] – R PC1 Secondary Side	D	2002-11-22	
506-556-02	1	TRY [HPP] – R PC1 Inner Layer 1	D	2002-11-22	
506-556-02	1	TRY [HPP] – R PC1 Inner Layer 2	D	2002-11-22	
506-557-02	1	TRY-HPP PC2 Primary Side	B	2002-11-22	
506-557-02	1	TRY-HPP PC2 Secondary Side	B	2002-11-22	
506-558-02	1	PC3, TRY-R HPP Primary Side	G	2008-09-30	
506-558-02	1	PC3, TRY-R HPP Secondary Side	G	2008-09-30	
506-558-02	1	PC3, TRY-R HPP Innaer Layer 1	G	2008-09-30	
235-476-00	1	PC1, TRY [HPP] –R Option (Schematic)	J	2006-08	
235-476-00	1	PC2, TRY [HPP] –R Option (Schematic)	J	2006-08	
235-476-00	1	PC3, TRY [HPP] –R Option (Schematic)	J	2006-08	
235-576-00	1	PC1, TRY [HPP] –R Option (PC Assembly)	C	2002-11	
235-577-00	1	PC2, TRY [HPP] –R Option (PC Assembly)	B	2002-11	
235-578-00	1	PC3, TRY [HPP] –R Option (PC Assembly)	F	2007-02	
235-579-00	3	Top Assembly, TRY-HPP –R Option (PC Assembly)	A	2000-03	
506-556-01	2	PC1, TRY [HPP] –R Option (PC Fabrication)	D2	2008-07	
506-557-01	2	PC2, TRY [HPP] –R Option (PC Fabrication)	B	2002-11	
506-558-01	2	PC3, TRY [HPP] –R Option (PC Fabrication)	G	2008-09	
235-569-00	1	Front Panel Sub-Assembly TRX / TRY –R Option (Mech Assembly)	A	2000-03	
200-251-1721	1	Label, ANZEx TRY-ISA [HPP], Intrinsically Safe	B	2009-10	
205-248-00	1	TRY Case Assembly – R Option Mech Assy)	B	2004-09	
204-284-01	1	TRX / TRY Case Top (Fabrication)	B	1995-06	
204-284-02	1	TRX / TRY Case Bottom (Fabrication)	A	1995-06	
235-710-01	1	TRY & TRX PC-Programmable Temperature Transmitters (Service manual)	N	2005-04	