

Alarm Trips and Switches

A8: Hard Alarm Required for Insurance Policy

Problem: We upgraded to a DCS with alarms programmed directly into the software, but our insurance company requires a hard alarm backup. Is that standard operating procedure?

Solution: Yes! Many plants are adopting the new standards that require redundant alarm devices... especially for critical loops or processes. We supply systems with varying levels of redundancy dependant on how critical the application. Safety Instrumented Systems may be designed modularly to meet most any requirement.

Model Number Example

SPA / HLP RG / 4PRG / U / -AO [DIN]

