



# Certificate / Certificat Zertifikat / 合格証

MII 1202038 C001

*exida* hereby confirms that the:

## SRM Safety Relay Module

**Moore Industries-International, Inc.  
North Hills, CA - USA**

The manufacturer  
may use the mark:



Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type A, Route 1<sub>H</sub> Device**

**PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

Revision 1.7 July 18, 2018

Surveillance Audit Due  
August 1, 2021

### Safety Function:

The Safety Relay Module Alarm is a relay repeater module. It accepts a single contact closure input and propagates the alarm state to three (3) relay outputs. The Monitor Output can also be used as part of a safety function.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



ANSI Accredited Program  
ISO/IEC 17065  
PRODUCT CERTIFICATION BODY  
#1004



*John C. Yozallinas*  
Evaluating Assessor

*[Signature]*  
Certifying Assessor

MII 1202038 C001

**Systematic Capability: SC 2 (SIL 2 Capable)****Random Capability: Type A, Route 1<sub>H</sub> Device****PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application****Systematic Capability:**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element.

**IEC 61508 Failure Rates in FIT\***

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$	SFF
SRM/CC/3RO/24DC [DIN]	0	129	0	62.5	67.4%

\* FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** MII 12/02-038 R001 V2 R2 (or later)

**Safety Manual:** 225-765-00G (or later)



80 N Main St  
Sellersville, PA 18960