

Fieldbus is simple. So simple, you'll wonder what all the fuss is all about. In this article, we'll stick to the two basic fieldbuses used in process control: PROFIBUS PA and FOUNDATION fieldbus™ H1. We'll cover how fieldbus works, show how to connect instruments, and explain why—in most cases—you can't connect all 32 instruments on a single fieldbus segment as all the advertising claims.

We will also talk about the differences between PROFIBUS and FOUNDATION fieldbus, FISCO vs. Entity intrinsically-safe fieldbus systems, installing redundant segments, and EDDL vs. FDT.

#### **How Fieldbus Works**

In analog controls systems, instruments produce a 4-20mA output signal that travels all the way from the remote distillation column, tank or process unit to the control room, marshalling rack, remote I/O concentrator or RTU over twisted pair cables. Similarly, 4-20mA control signals travel from the control system to valve actuators, pumps and other control devices. Hundreds, sometimes thousands, of cables snake their way through cable trays, termination racks, cabinets, enclosures and conduit (Figure 1).

The availability of low cost, powerful processors suitable for field instrumentation now opens the way to remove the bulk of these cables and, at the same time, enhance data available from the plant.

Instead of running individual cables, fieldbus allows multiple instruments to use a single cable, called a

*Figure 1.* Traditional 4-20mA field wiring often results in a rat's nest of wires, cables and terminations.



Photo Credit: Genzyme

Figure 2. A fieldbus installation substantially simplifies wiring.



"trunk" or a "segment," (Figure 2); each instrument connects to the cable as a "drop." Instruments, of course, must have a fieldbus interface to connect to the segment, and some sort of software running to provide the fieldbus communications.

A fieldbus trunk or segment—either FOUNDATION fieldbus H1 or PROFIBUS PA—is a single twisted pair wire carrying both a digital signal and DC power that connects up to 32 fieldbus devices (temperature, flow, level and pressure transmitters, smart valves, actuators, etc.) to a DCS or similar control system. Most devices are two-wire bus-powered units requiring 10 to 20mA, but it is also possible to have 4-wire fieldbus devices, typically where a device has a particularly high current draw.


The fieldbus segment begins at an interface device at the control system. On a FOUNDATION fieldbus H1 (FF) system, the interface is called an H1 card; on a PROFIBUS PA system (PA), it is a PROFIBUS DP/PA segment coupler. In terms of signal wiring and power requirements for the segment, FF and PA are identical:

- Minimum device operating voltage of 9V
- Maximum bus voltage of 32V
- Maximum cable length of 1900m (shielded twisted pair)

The DC power required by the bus is normally sourced through a fieldbus power supply or "power conditioner" which prevents the high frequency communications signal from being shorted out by the DC voltage regulators. Typical power conditioners make 350 to 500mA available on the bus and usually incorporate isolation to prevent segment-to-segment cross talk. For PA, the "segment coupler" usually incorporates the power conditioning component. In FF segments, the power conditioners are separate from the H1 interface card and are often installed in redundant pairs to improve the overall reliability. Figure 3 shows a typical fieldbus segment.

When calculating how many devices can fit on a fieldbus segment, a user must take into account the maximum current requirement of each device, the length of the segment (because of voltage drops along the cable), and other factors. The calculation is a simple Ohm's law problem, with the aim of showing that at least 9V can be delivered at the farthest end of the segment, after taking into account all the voltage drops from the total segment current. For example, driving 16 devices at 20mA each requires 320mA, so if the segment is based on 18AWG cable (50 Ohms/km/loop) with a 25V power conditioner,

**Figure 3.** A fieldbus segment starts with an H1 interface card and a power supply for FOUNDATION fieldbus or a segment coupler for PROFIBUS. Up to 32 devices can be supported on a single segment. The boxes with a "T" in them indicate the location of the segment terminators.




the maximum cable length is 1000m to guarantee 9V at the end. Note that many users also specify a safety margin on top of the 9V minimum operating voltage, to allow for unexpected current loads and adding additional devices in the future.

### **Connecting Instruments**

As noted, each fieldbus device connects to the segment in parallel, via a "drop" on the fieldbus segment called a spur. The simplest spur connection is a "T." The problem with simple "T" connections (Figure 4), is that if any one of the devices or cables short out, it takes down the entire segment. A short can occur during field maintenance of an instrument, from an accident in the field, corrosion causing electrical problems, or a host of other possibilities. Short-circuit protection is therefore a requirement for proper fieldbus implementation.

*Figure 4.* "T" configurations are the simplest fieldbus connection. However, if one device fails or short-circuits, it "takes down" the entire segment.




Another way to connect fieldbus devices is via junction boxes specifically designed for fieldbus, often referred to as "device couplers"—such as the MooreHawke™ TG200 TRUNKGUARD™ (Figure 5)—that allow multiple fieldbus devices to connect at one location. Typically, users will install a device coupler in a field enclosure, and connect nearby instruments to it. The fieldbus cable may continue onward to another device coupler. A multi-instrument segment may have several device couplers.

Two basic types of electronic spur short-circuit protection are used in device couplers: "current limiting" and "foldback." Both prevent a spur fault from shorting out the segment and both auto-reset back to normal on removal of the fault.


The current-limiting technique limits the amount of power the short circuit can draw to between 40 and 60mA (vendor dependent) but it also holds that fault on the segment continuously. Although this design protects the segment from the initial short, the additional current draw can deprive other instruments on the segment of power, overload the segment power supply, and possibly cause catastrophic failures on the segment.

When a short circuit deprives other instruments of power, some may "drop off" the segment because they do not have enough power to operate properly. Consequently, when current limiting protection is used in a device coupler, many end users allow a safety margin. That is, **Figure 5.** A device coupler permits multiple instruments to be connected to a fieldbus segment. Each "spur" has short-circuit protection, so it cannot harm the entire segment. More than one device coupler can be used in a segment.



they do not install as many instruments as the segment can theoretically power; instead, they leave a certain number of spurs empty.

For example, if a user wants the segment to be able to keep working with two failures—which can draw up to 120mA of current—the segment calculations must assume a maximum current availability of 350mA minus 120mA for the faults, or 230mA. **Figure 6.** Fold-back short circuit protection has logic that detects a short, removes the shorted circuit from the segment, and lights an LED. This prevents a short from affecting the segment.



Instead of theoretically being able to power 32 devices that draw 10mA each, the segment is now only able to support 23 such devices. In practice, some users are wary of relying on current limiting couplers, and most limit each segment to only 16 devices to prevent large-scale segment failures.

The fold-back technique, as used in MooreHawke's TRUNKGUARD Device Couplers, disconnects the shorted spur from the segment, thus preventing loss of an entire segment. The fold-back technique has a logic circuit on each spur (Figure 6) that detects a short in an instrument or spur, disconnects that spur from the segment, and illuminates a red LED that can be seen by maintenance personnel.

With fold-back device couplers, users no longer have to worry about spur failures and can have confidence about placing more devices on fieldbus segments. Since the cost of H1 cards (\$2,500) and other segment hardware can be cost-prohibitive, being able to place more devices on a segment can save users a considerable amount.

### **Segment Termination**

Every fieldbus segment must be terminated at both ends for proper communication. If a segment is not terminated properly, communications errors from signal reflections may occur. Most device couplers use manual on/off DIP switches to terminate couplers. In a segment, the last device coupler should contain the terminator, and all couplers between the last coupler and the H1 card should have their terminator switches set to off.

The boxes with a "T" in Figure 3 and 5 illustrate where a typical segment is terminated properly.

A frequent commissioning problem during startup is determining that terminators are correctly located. During

installation of the fieldbus system, the DIP termination switches sometimes are set incorrectly, creating problems during startup. The instruments can behave erratically, drop off the segment mysteriously, and generally raise havoc—all because the terminations are not set properly.

Diagnosing the problem often requires physically examining each device coupler to determine if the switches are set properly throughout the segment.

Automatic Segment Termination, as found in TRUNKGUARD Device Couplers, simplifies commissioning and startup. It automatically activates when the device coupler determines that it is the last fieldbus device coupler in the segment; if it is, it terminates the segment correctly. If it is not the last device, it does not terminate the segment, since the downstream device coupler will assume that responsibility. No action—such as setting DIP switches—is necessary by the installation person to terminate a segment properly.


If a device coupler is disconnected from the segment accidentally or for maintenance, the Automatic Segment Termination detects the change, and terminates the segment at the proper device coupler. This allows the remaining devices on the segment to continue operation.

### **Redundant Fieldbuses**

Fieldbus has one major problem: all communications and power are dependent upon a single twisted pair trunk cable. If the trunk cable fails, it can "take down" all the devices on the segment at one time. Not only is the fieldbus segment lost to the control system, devices on the segment can no longer talk to each other. Although fieldbus instruments can continue to operate if the control system fails, any cable fault (open or short-circuit) could render the entire segment inoperable.

This problem is especially serious on plant-critical segments, where the failure of a segment may adversely affect plant or process applications, lead to costly process shutdowns, cause a hazardous condition, or release materials into the environment.

No provision is made within either fieldbus standard for redundant segment communications. Various fieldbus vendors, including major process control companies, have developed redundant fieldbus schemes that involve complete duplication of all equipment—including H1 or DP/PA interfaces, power supplies, fieldbus cables, device couplers, and some critical fieldbus instruments (Figure 7)—plus complex software voting schemes. **Figure 7.** Some fieldbus redundancy techniques require complete duplication of the segment; in some cases, this means duplicate field instruments. When a segment fails, logic in the DCS determines that a failure has occurred, and switches from one H1 card to the other.



A "voting scheme" is needed because most control systems cannot tell when a fieldbus segment fails. They can only detect if the H1 or DP/PA interface itself fails, or if a particular fieldbus device fails. If the interface remains powered, the control system has to determine, by analyzing instrument signals (or the lack thereof), that the entire segment has failed.

Needless to say, such redundancy schemes are expensive, complex, and can be hard to maintain. A catastrophic process failure could result while the control system is determining what's wrong.

The prospect of losing an entire critical segment often makes end users wary of fieldbus. If a segment contains "process-critical" instruments, they generally limit the number of instruments per segment to only a few, or spread critical instruments over multiple redundant segments.


MooreHawke has solved the redundancy problem for FOUNDATION fieldbus systems.

MooreHawke's TRUNKSAFE™ Fault-Tolerant Fieldbus System provides a highly-reliable way to maintain continuous communications between field devices and a DCS in the event of any single point failure (such as openor short-circuit) on a FOUNDATION fieldbus segment.

TRUNKSAFE (Figure 8), consists of dual, redundant TPS200 Advanced Fieldbus Power Conditioners (one for each leg of the segment), two fieldbus cables, and a TRUNKSAFE TS200 Device Coupler.

The power conditioners are located on DIN carriers for up to four segments at a time and the device couplers accommodate six or 10 fieldbus instruments.

**Figure 8.** The TRUNKSAFE Fault-Tolerant Fieldbus System only requires an extra power conditioner and a trunk cable. If one segment fails, it instantly switches over to the backup segment.



In a typical TRUNKSAFE application, two redundant H1 interface cards are connected to two legs of a fieldbus segment, and wired out into the field. The power on each leg is properly conditioned by the TRUNKSAFE Power Conditioner, and run to the TRUNKSAFE Device Coupler, which are connected to multiple fieldbus devices. The installer routes the fieldbus cables separately, so that the same incident (a careless forklift driver, for example) does not take both cables out at the same time.

If a fault occurs on either cable, the power conditioner on the affected leg immediately cuts power to that leg and its H1 interface, which forces the DCS to switch to the alternate H1 card. The device couplers can be driven by either trunk; if one trunk loses power, the device coupler automatically takes its power from the remaining trunk and applies the segment terminator. This all takes place automatically within a few milliseconds.

With TRUNKSAFE, it may not be necessary to duplicate all fieldbus instruments in a critical segment. An end user may decide to duplicate an instrument if the device itself is prone to failure, but it is no longer necessary to duplicate instruments for protection against a trunk failure.


The cost of a fully-redundant TRUNKSAFE Fieldbus System is only slightly more than a standard fieldbus system, and far less than that of a fully-duplicated system. In fact, the availability of an inexpensive, fully fault-tolerant FF system now makes it possible for end users to provide redundancy on more than just processcritical loops.

### Intrinsically-Safe Operation: Entity vs. FISCO

Fieldbus systems are suitable for use in many hazardous areas; that is, wherever standard 4-20mA instruments can be used. All forms of electrical protection (non-incendive, flameproof, intrinsically-safe) are available to suit the requirements of any site preference or experience, but having multiple devices on the same wire pair does lead to additional design issues. Intrinsically-safe systems are particularly difficult since it is hard enough delivering power for a single instrument; driving 10 or 16 devices is a real challenge, for which various solutions now exist based on Entity, FISCO or split-architecture configurations.

Entity solutions have been around since the 1950s. The Entity concept is based on using barriers and power supplies to limit the amount of energy that can enter a hazardous area (Figure 9). In general, Entity systems are highly reliable, especially when based on simple resistive

**Figure 9.** Entity-type systems use barriers and electronic techniques to limit the amount of current entering a hazardous area. This technique has been used since the 1950s, and is the basis for most fieldbus intrinsically-safe systems, but it only allows 4-5 instruments on a fieldbus segment.




current-limiting. Intrinsically-safe fieldbus was originally based on the FOUNDATION fieldbus FF816 specification, which allowed Entity parameters for field devices to be at least 24V/250mA/1.2W. The barriers that were available initially only allowed around 80mA for Gas Groups A, B, C, D (NEC)/II (IEC), or four devices per segment, which is an unacceptably low number of devices in a practical application.

FISCO stands for Fieldbus Intrinsically Safe Concept. It is based on work done by Physikalisch-Technische Bundesanstalt (PTB), the national metrology institute in Germany, and involves physically testing complete systems to ensure safety and to derive an envelope specification into which every component has to fit. To provide a FISCO solution, every part of that system, including devices, power conditioners and cable, has to comply with strict limits. These efforts by PTB and others enable FISCO power supplies to generate up to 110mA in Group A&B applications, and 250mA in Group C&D. FISCO power supplies are based on sophisticated electronic current-limiting, and therefore tend to be expensive, quite complex, and typically have lower MTBFs than conventional fieldbus power conditioners. With only 110mA available in Group A&B, a FISCO-type system can support only four to five devices per segment (allowing a maximum of 20mA per instrument plus power for the device coupler plus power losses over distance). In a plant with 250 instruments, this would require 50 to 60 FISCO segments. Considering that each segment requires an H1 card (\$2,500) plus a power supply, plus a device coupler, plus a fieldbus cable, the total cost for FISCO hardware alone would be about \$5,000 per segment times 50-60 segments, or \$250,000 to \$300,000.

This does not count the time and labor involved in running 50 to 60 fieldbus segments into the plant, installing the consoles, enclosures and device couplers, and wiring all the components. This could cost an additional \$100,000.

MooreHawke's ROUTE-MASTER™ Entity Fieldbus System is based on a "split-architecture" approach to the barrier. Part of the barrier is in an isolator (back-of-panel) and part of it is in each of the spurs of a field-mounted

*Figure 10.* The split-architecture Entity approach used in ROUTE-MASTER puts part of the barrier in the power supply, and the other part of the barrier in the field. This allows up to 16 instruments to be powered on an intrinsically-safe fieldbus segment.




Demand Moore Reliability • www.miinet.com

device coupler (Figure 10). By splitting the intrinsicallysafe current-limiting method in this unique way, the ROUTE-MASTER can put a full 350mA on the trunk that leads into hazardous areas with Gas Groups C&D, and still have intrinsically-safe spurs that match FF816 Group A&B approved devices. This overcomes both the FISCO and conventional Entity restrictions on available current. Instead, up to 16 devices can be put on a segment, nearly four times as many as a FISCO system, with a greatly reduced cost for hardware and labor.

MooreHawke has a segment calculator (Figure 11), that helps calculate the number of devices per segment, based on the current and voltage requirements of each device, length of the segment, and other factors. It also bases its calculations on a requirement that each device receives at least 9V.

**Figure 11.** This segment calculator determines current and voltage requirements for a segment, and makes sure that all devices receive at least 9V of power.



Most people are concerned with the amount of current each device draws from the fieldbus segment. However, the amount of voltage available at the field device is also a critical variable. For example, if devices on the segment draw too much current, and the segment has a long run, the increased current draw may result in too much voltage drop; consequently, some devices may get less than 9V. Although the devices get enough current, they do not get enough voltage.

The MooreHawke ROUTEMASTER system can support two trunk cables for each segment. The two trunks run separately from the power conditioner to the field devices, but they are part of the same segment. Instead of one long segment, it uses two shorter trunks. Therefore, the total segment distance on each trunk leg is minimized, reducing the amount of voltage drop, and providing more than 9V to each device.

### FOUNDATION Fieldbus H1 vs. PROFIBUS PA

From a field wiring perspective, FOUNDATION fieldbus and PROFIBUS are physically identical. They use the same twisted-pair cables and device couplers, and require the same segment terminators. Both handle up to 32 devices per segment.

One primary difference is that PROFIBUS is a polling system, while FOUNDATION fieldbus utilizes cyclic transmission. Other differences include:

- FF devices have scheduled times at which they transmit their information, whereas PA devices submit their data at random times. In PA, slave polling involves the bus master asking for information from the devices. The link active scheduler in FF has a timetable, so it determines when devices communicate on the segment.
- Address allocation in PA has to be done by communication with each device individually, whereas FF devices will announce themselves to the bus master.
- Each PA device will go back to the bus master with its info, which will then transmit to other devices the relevant data. FF devices can talk to each other and bypass the bus master, hence providing peer-to-peer communication.
- FF devices can have built-in function blocks that allow them to talk to each other peer-to-peer, perform control functions, and continue to operate if communications are lost to the control system.
  PROFIBUS systems do not have function block capability. PROFIBUS instrumentation reports to and takes directions from the PA master; if communications to the PA Master(s) are lost, the instruments must go to a fail-safe position or maintain their last settings until directed otherwise.
- FF and PA differ in the way that the segment control cards connect to the DCS or control system. FF uses an HSE (high speed Ethernet) network to connect remote H1 cards to the DCS; PA uses PROFIBUS DP, which is an RS-485 network, or PROFINET, an Ethernet-based network, to connect its PA devices to the DCS.

### **DD, EDDL and FDT**

Both FF and PA systems require that instruments and controllers be "mapped" into the control system. That is, the DCS or control system must be told what devices are on the segment, what variables are to be input and output, and what functions are available. This is usually done with Device Description (DD) files, which are text-based

files that can be downloaded from a web site into either an FF or PA-based control system. For example, DD files from all FF devices that have received FF certification can be downloaded from the Fieldbus Foundation web site. In general, DD files are universal; that is, they can be used in either a FF or PA system. During control system commissioning, DD files are downloaded into the control system's equipment configuration. DD provides a standardized representation for the device that allows the host to interact with the device and allows the host to provide a consistent user interface for devices that is independent of the device type.

EDDL (Electronic Device Description Language) and FDT/ DTM (Field Device Tool and Device Type Management) are more advanced ways to describe devices. Typically, EDDL is used by FF systems, while FDT/DTM is used by PA systems, but the two technologies are growing closer.

EDDL starts with DD files. The DDL (Device Description Language) is the method for writing DD files. The next generation is EDDL (Electronic DDL), which provides additional information for GUI displays, configuration and calibration procedures, alarms and interfaces to higherlevel software, such as MES, SCADA and plant historians. EDDL is independent of devices and operating systems.

DTMs are vendor-specific drivers that interact with the device. DTMs allow more sophisticated programs to be written, so configuration and management tools such as PACTware can be used to configure and view vendor specific data. They are also dependent on the host operating system, while EDDL is not.

To process the EDDL or FDT files, each control system vendor must have software capable of reading and understanding the files. For a while, a controversy existed in the fieldbus world, where some FF vendors would not accommodate FDT/DTM files, and vice versa. Fortunately, two of the biggest control system vendors recently agreed to patch up their differences and support both systems, so the EDDL vs. FDT controversy appears to be ending. Soon, most control system vendors will support both EDDL and FDT.

An end user must ensure that all the instruments and field devices planned for a control system conform to the chosen fieldbus. If, for example, a FF system with EDDL is chosen, then all the instruments must have EDDL or

> Australia • sales@mooreind.com.au Tel: (02) 8536-7200 • FAX: (02) 9525-7296

DD files; conversely, a PB system with FDT/DTM must use instruments that have those files. Fortunately, it is relatively easy to check, simply by consulting the web sites for FF or PA.

### **Justifying Fieldbus**

Fieldbus was initially justified by the considerable cost savings that resulted from using less wiring. Instead of running hundreds or thousands of wires, fieldbus often required only a few dozen segments or trunks.

In recent years, the savings from running cables has been offset by the high cost of fieldbus components, and the reluctance of many users to install all the instruments possible on a segment. Being forced to provide for short circuits, for example, limits the number of instruments that can be put on a segment. In many cases, it's a tossup, from a hardware cost and labor perspective. In other cases, when the full capability of a segment can be used, hardware cost savings become more realistic.

The true advantage of fieldbus is its ability to diagnose equipment problems, cut maintenance costs, provide information for asset management, allow control at the device level, and allow the use of smart devices. One oil company in Alaska did a study of savings it found by using a FOUNDATION fieldbus system. The savings included:

- Wiring They achieved a 98% reduction in homerun wiring because with fieldbus they could eliminate the costly maze of wiring between each remote field instrument and the control room. Terminations were also reduced by 84%.
- Control room Fewer terminations also freed up two-thirds of the cabinet space that would be required with traditional technology.
- **Commissioning** Field check-out and QA/AC time was reduced by 83%. Installation of each transmitter took only 20 minutes rather than the two hours needed with non-fieldbus technology.
- Engineering drawings Reduced the effort required for new drawings when adding oil wells by 92% because of FOUNDATION fieldbus and the host system's configuration tools and objectoriented capabilities.

The oil and gas industry was the first to fully embrace fieldbus, and now installs it at many new refineries, offshore platforms and other facilities.

All product names are the property of their respective companies.



United States • info@minet.com Tel: (818) 894-7111 • FAX: (818) 891-2816 BeNeLux • info@mooreind.eu

BeNeLux • info@mooreind.eu Tel: 03/448.10.18 • FAX: 03/440.17.97 China • sales@mooreind.sh.cn Tel: 86-21-62491499 • FAX: 86-21-62490635 United Kingdom • sales@mooreind.com Tel: 01293 514488 • FAX: 01293 536852

700-7D6-03A